



FORESTFLO®

Cotton / synthetic jacket combined with our Hydro-Wick® weeping process provides maximum heat protection



Applications

- Forestry light weight, self-protecting, attack hose
- Urban interface, grass fire kits, and mop up hose

Features and Benefits

- Cotton / synthetic single jacket
- Patented Hydro-Wick® weeping process producing a “wick” effect to dampen the hose jacket
- Standard treatment of cotton jacket includes anti-fungal and anti-microbe as per ULC S518/S519 and CGSB CAN2-4.2 method 28.3
- Light weight and compact with superior heat and abrasion resistance
- Unique Mertex® lining yields an extremely low friction loss, for maximum flow and superior adhesion for long life
- Meets or exceeds all performance requirements of NFPA 1961, ULC S519 and ULC 400° C Hot Block test
- Meets ULC requirements S519 and can be labeled upon request in the sizes* specified below
- Resistant to most chemicals, petrol products, ozone and U.V. exposure, and hydrolysis

DIAMETERS

1.00in/25mm ●

1.50in/38mm ●

Hose Spec	Trade Size		Bowl Size		Weight Un-coupled 100'(30.5M)		Coil Diameter 100'(30.5M)		Service Pressure		Proof Pressure		Burst Pressure	
	In.	mm	In.	mm	LBS	Kg	In.	Cm.	PSI	kPa	PSI	kPa	PSI	kPa
762	1.00	25	1 5/32	29	8.5	3.9	15.0	38.1	300	2 070	600	4 140	900	6 200
707	1.5*	38*	1 11/16	43	12.0	5.5	15.0	38.1	300	2 070	600	4 140	900	6 200

5838 Cypihot
 Saint Laurent, QC
 Canada, H4S 1Y5

Phone 514.335.4337
 Phone 877.937.9660
 Fax 514.335.9633

mercedestextiles.com
 sales@mercedestextiles.com



HOW TO SPECIFY **FORESTFLO®**

THE HOSE SHALL BE SINGLE JACKET WITH A SERVICE TEST PRESSURE OF 300 PSI / 2070 KPA.

JACKETS

The jacket shall be made with 100% virgin spun cotton and filament polyester warp yarn and high tenacity filament polyester filler yarn tightly woven in twill weave and shall have a minimum filler (weft) yarns of 12.7 per inch (500 per Meter).

The hose shall be self-protecting by percolating just the right amount of water through the jacket for even protection along its entire length. This Weeping process shall be achieved by weaving the yarn through the liner thus producing a "Wick" effect to dampen (wet) the hose jacket.

LINING

The lining (waterway) must be made from polyurethane and must be applied using a fused process that welds the polyurethane directly to the textile while the hose is being woven, without the use of adhesives or hot melt. The fused lining process must create a virtually inseparable unit without the use of adhesives, yielding an extremely low friction (pressure) loss by filling in the corrugations of the weave, creating an ultra thin and smooth waterway. Fire hose made using adhesives of any type do not meet this specification. The lining shall be approved for use with potable water.

ADHESION

The adhesion shall be such that the rate of separation of a 1 1/2" / 38mm strip of polyurethane, transversely cut, shall not be greater than 1/4" / 6mm per minute under a weight of 12 lbs / 5.5 kg.

FLOW AND FRICTION LOSS

The 1 1/2" (38 mm) hose shall be capable of flowing 70 US GPM (264 LPM) with a maximum pressure loss of 10 PSIG (69 kPa) per 100' (30.5M).

SERVICE, TEST, BURST PRESSURES

Minimum service, test and burst pressures shall be as detailed in the specification table on the previous page.

KINK TEST

A full length will withstand a hydrostatic pressure of 600 psi / 4140 kPa while kinked.

WEIGHT

Each length of fire hose shall not weigh more than indicated in the specification table.

COUPLING SPECIFICATIONS

Couplings shall be in conformance with the current NFPA standard and made of extruded aluminum, hard coated a minimum of .002" thick. They shall be manufactured in North America and permanently labeled with country of origin.

The hose shall be available with threaded and quarter-turn threadless (QC) couplings. When quarter-turn threadless (QC) couplings are specified they shall have extended lugs to facilitate rapid connect and disconnect.

MANUFACTURE

Both hose and couplings must be manufactured in North America and be NAFTA compliant.

STANDARDS

The hose shall be ULC approved and can be labeled upon request in the sizes specified*

Fire hose manufactured to this specification shall meet or exceed all performance requirements of NFPA 1961, ULC S519 and ULC 400°C Hot Block test.

The hose jacket treatment shall include anti-fungal and anti-microbe as per ULC S518/S519 and CGSB CAN2-4.2 method 28.3.